

Office of the Chief Medical Officer Allahabad

Certificate of Safe Drinking water and Sanitary Condition

Letter N.-CMO/Epi/Drinking water/2019-20/ 9497

Date: 23-12-2020

To,

The Principal,

Khelraon Public School

Prayagraj.....

It is Certified that an inspection team handed by C.M.O.
Prayagraj.... from Health Department Office of the Chief Medical
Officer, Allahabad U.P. inspected the ...Khelraon...Public...School....
School/College on 22.12.2020.. and found that the..Khelraon...Public
School/College has safe drinking water facilities for the students and members
of Staff of the institution and is maintaining the hygienic condition in the School
building and the camps as per the norms prescribed by Central/State/ U.T.
government.

The above valid for a period ofONE YEAR'S.....

Chief Medical officer,
Allahabad

मुख्य चिकित्सा अधिकारी
प्रयागराज

संख्या C 9854

जल-कल विभाग, नगर निगम, इलाहाबाद
(नगद प्राप्ति रसीद)



रसीद संख्या

17

श्री / श्रीमती		क्र. सं.	मद	अवशेष	वर्तमान	योग	छूट
भवन सं		1	2	3	4	3+4=5	6
वार्ड सं		1.	संचालित मद				
से प्राप्त किया।		2.	जल कर	जल पर शुल्क		500/-	
अवधि		3.	सीवर कर				
बिल सं		4.	स्थाई जल मूल्य				
देय तिथि		5.	अति 0 जलमूल्य				
मीटर सं		6.	सलेज जलमूल्य				
ले. फो. सं		7.	मीटर किराया				
		8.	सर्विस चार्जेज				
		9.	समझौता शुल्क				
			अन्य चार्जेज				
(केवल कार्यालय प्रयोग हेतु)		योग :-				500/-	
लेजर सं		1.	असंचालित मद				
के पृष्ठ सं		2.	मीटर जमानत				
पर जमा की प्रविष्टि की गयी।		3.	विकास शुल्क				
अभिप्रमाणित		4.	डिपॉजिट कार्य के विरुद्ध अग्रिम				
लेखा पदाधिकारी		योग :-				500/-	

कुल योग (शब्दों में) रु 500/-

कुल योग

दिनांक 25/01/20

रसीद बनाने वाले का हस्ताक्षर पद

कैशियर हस्ताक्षर



ALLAHABAD JAL KAL VIBHAG LABORATORY
CHEMICAL ANALYSIS OF WATER
Test Report

कार्यालय महानगर नगर निगम
जलकल विभाग-नगर निगम
प्रयागराज

पत्र संख्या 774/म.प्र.ज.क.वि./201 202
दिनांक 25/01/2020

Sl. No.

- Source of Sample *Water Sample Khelgaon public school prayagraj from Principal*
- Date of Sampling *19-1-2020*
- Date of Analysis *19-1-2020*

Physico Chemical Parameter	BIS Limit IS 10500 : 1991		Result of Test
	Requirement (Desirable Limit) mg/l	Permissible limit in the absence of alternate source mg/l	
4. Total Dissolved solids	500	2000	349
5. Free and saline Ammonia	NS	NS	—
6. Albuminoid ammonia	NS	NS	—
7. Dissolved Oxygen	min 5.0	NS	—
8. Hardness Total as CaCO ₃	300	600	288
(a) Temporary as CaCO ₃	NS	NS	144
(b) Permanent as CaCO ₃	NS	NS	144
9. Chlorine as Chlorides Cl	250	1000	90
10. Total Alkalinity as CaCO ₃	200	600	45
11. Nitrites as NO ₂	NS	NS	Nil
12. Nitrates as NO ₃	45	100	Nil
13. Iron as Fe	0.3	1.0	0.1
14. Fluoride as F	1.0	1.5	0.6
15. Colour Hazen Unit	5	25	Colourless
16. Taste	Agreeable		Not tasted
17. Odour	Unobjectionable		Odourless
18. pH Value	6.5 to 8.5 No relaxation		8.0
19. Conductivity as μ mhos at 20°C	NS	NS	498
20. Turbidity NTU	5	10	1.2
21. Free Residual Chlorine	0.2	NS	Nil

Remarks

Potable

[Signature]
Chemist

End. No.

J.K.

[Signature]
Ex. Engg. (HQ)

अधिसायी अभियन्ता (मुख्यालय)
Dated : Allahabad 20/01/2020

जलकल विभाग, नगर निगम
प्रयागराज

Copy forwarded for information to :

- The Addl. Director, State Health Institute, Sector-C, Chetan Vihar, Aliganj, Lucknow, U.P.
- Chief Medical Officer, Allahabad.
- Mukhya Nagar Swasthya Adhikari, Nagar Nigam, Allahabad.
- Nagar Ayukta, Nagar Nigam, Allahabad.
- The Superintending Engineer (R & D), Office of Addl. Chief Engineer (PPR & D), U.P. Jal Nigam, 6, Rana Pratap Marg, Lucknow.
- Chairman, Jal Kal Vibhag/Mayor, Nagar Nigam, Allahabad

Ex. Engg. (HQ)

ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample
 Name & Designation of the person collecting the sample Dr. R.C. Shrivastava & Principal

S.No.	Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count			Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks	
				At 37°C in 48 hours	At room temperature in 72 hours	Quantity of water put up in each tube/No. of tubes put up	50 ml.	10 ml.				1 ml.
							1	5				5
	19-1-2020	19-1-2020	Water Sample Khalgaon public school Prayagraj				0	0	0	0	Nil	Excellent

[Signature]
 Chemist

~~Chief Chemist~~

[Signature]
 Ex. Engineer (HQ)
 अधिशाही अभियन्ता (मुख्यालय)
 जलकल विभाग, नगर निगम
 प्रयागसिटी