



कार्यालय अधिकांशी अभियन्ता (मु०)  
जलकल विभाग-नगर निगम प्रयागराज  
पत्र सं० ५४ मु० ज० क० वि०  
दिनांक ३०/०५/२५

## JAL KAL VIBHAG NAGAR NIGAM PRAYAGRAJ CHEMICAL ANALYSIS LABORATORY

Report No. DW/01/LAB2025-05/11

Date: 30.05.2025

### DRINKING WATER ANALYSIS REPORT

1	Name & Address	KHEL GAON PUBLIC SCHOOL, KHEL GAON, PRAYAGRAJ
2	Sample Collected by	By Party
3	Nature of Sample	Drinking Water
4	Date of Sample Collection	26.05.2025
5	Date of Sample Receiving	26.05.2025
6	Date of Analysis Completed	30.05.2025

S.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500-2012)	
				Desirable Limit	Permissible Limit
1.	Colour, units.	-	Colourless	-	-
2.	Odour	Agreeable	Odourless	Agreeable	-
3.	Temperature	°C	30.1	-	-
4.	Turbidity	NTU	0.5	5	10
5.	Conductivity at 25°C	µmho/cm	128.0	-	-
<b>CHEMICAL PARAMETERS</b>					
6.	pH	-	7.5	6.5 to 8.5	No Relaxation
7.	Suspended Solids	mg/L	Nil	-	-
8.	Dissolved Solids	mg/L	62.0	500	2000
9.	Total Solids	mg/L	62.0	-	-
10.	Total Alkalinity (as CaCO <sub>3</sub> )	mg/L	40.2	200	600
11.	Total Hardness (as CaCO <sub>3</sub> )	mg/L	72.4	200	600
12.	Chlorides (as Cl)	mg/L	41.0	250	1000
13.	Fluoride (as f) mg/l	mg/L	Nil	1.0	1.5
14.	Nitrate (as NO <sub>3</sub> )	mg/L	0.21	45.0	100.0
15.	Iron (Fe)	mg/L	Nil	0.3	1.0
<b>BACTERIOLOGICAL PARAMETERS</b>					
16.	Total Coliform	MPN/100ml	Absent	Absent	-
17.	E. Coli	MPN/100ml	Absent	Absent	-

\*Note: The water is suitable for drinking purposes-

Analyst

(Laboratory In-charge)

JE(HQ)

अधिकांशी अभियन्ता (मु०)  
जलकल विभाग  
नगर निगम प्रयागराज  
E.E(HQ)

- Note:
1. The above results are related only to the test performed on the sample.
  2. This report is not to be reproduce wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.
  3. Sample will be destroyed in the after fifteen days from the date of reporting.